

CORRIGENDUM - I

KAMARAJAR PORT LIMITED (A MINI Ratna Government of India Undertaking)

Tender No: KPL/ OP/ELE/10/2019

E-Tender for “Providing illumination to the Coal Berth 3&4 at Kamarajar Port”

1. The Line no.9 in page no.92 of 120 in Clause no.3.6.2 in Vol-I, Section-5. Site Conditions and Specifications of tender document is amended and to read as under.

Max. Wind sped: 55m/s as per IS-875 Part-3.

2. The Line no.1 in page no.89 of 120 in Clause no.3.6.2 in Vol-I, Section-5. Site Conditions and Specifications of tender document is amended and to read as under.

Two/Three continuous lengths of stainless steel wire ropes shall be used in system and no intermediate joints are acceptable in view of the required safety.

3. The Line no.4 in page no.110 of 120 in Clause no.3.6.3.3.1 in Vol-I, Section-5. Site Conditions and Specifications of tender document is amended and to read as under.

The LED shall have a colour temperature of 5700-6500K. The tolerance shall be as per ANSI standard.

4. The Line no.21 in page no.110 of 120 in Clause no.3.6.3.3.1 in Vol-I, Section-5. Site Conditions and Specifications of tender document is amended and to read as under

Note: LM79 test report from Central Power and Research Institute (CPRI) / Indian Institute of Technology (IIT) / National Test House (NTH) and LM 80 test report from the manufacturer to be submitted along with the supply of materials. The cost for testing shall be borne by the tenderer.

**Deputy General Manager (Civil)
Kamarajar Port Limited**